



Certificate of Compliance

Certificate: 2393617

Master Contract: 155891

Project: 2506141

Date Issued: March 12, 2012

Issued to: Dynalco

A Crane Co. Company
3690 N W 53rd St
Fort Lauderdale, FL 33309-2478
USA
Attention: Jose Rivero

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Sorin Tat

Issued by: Sorin Tat

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 2, Groups A, B, C and D

Universal Meter Series, Models UM-600, Catalyst Monitor, and UM-200 , input power rated 10Vdc to 36Vdc, 0.15A maximum, Alarm Outputs rated 40Vdc max, 0.15 Amps max, Maximum Ambient Temperature 70°C, Temperature Code T3C (160°C).

Notes:

The Universal Meter Series is connected per installation drawings A80012970 or A80012971 located in the instruction manual. The Universal Meter Series must be mounted in a suitable enclosure. The final installation shall be subjected to acceptance of local authority having jurisdiction.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 0-10 - General Requirements - Canadian Electrical Code Part II



Certificate: 2393617

Master Contract: 155891

Project: 2506141

Date Issued: March 12, 2012

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 916:2007 - Energy Management Equipment

ANSI/ISA 12.12.01:2007 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division 1 and 2 Hazardous (Classified) Locations